

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-LT-6101-2026 Revision: A

Title: Calibration record, LT-6101

Owner: Gopal Iyer

Issued: 05 August 2026

Primary equipment: LT-6101, Tank 1 level

Tester: Gopal Iyer

Equipment: LT-6101

As-found error 0.12 percent of span.

As-left error 0.04 percent of span.

Loop check and tag confirmed.

Result: passed.