

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-LT-6102-2025 Revision: A

Title: Calibration record, LT-6102

Owner: Gopal Iyer

Issued: 02 September 2025

Primary equipment: LT-6102, Tank 2 level

Tester: Gopal Iyer

Equipment: LT-6102

As-found error 0.18 percent of span.

As-left error 0.01 percent of span.

Loop check and tag confirmed.

Result: passed.