

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-LT-6103-2025 Revision: A
Title: Calibration record, LT-6103
Owner: Gopal Iyer
Issued: 17 October 2025

Primary equipment: LT-6103, Tank 3 level

Tester: Gopal Iyer
Equipment: LT-6103

As-found error 0.18 percent of span.
As-left error 0.01 percent of span.
Loop check and tag confirmed.
Result: passed.