

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-LT-6104-2025 Revision: A

Title: Calibration record, LT-6104

Owner: Gopal Iyer

Issued: 13 September 2025

Primary equipment: LT-6104, Tank 4 level

Tester: Gopal Iyer

Equipment: LT-6104

As-found error 0.17 percent of span.

As-left error 0.01 percent of span.

Loop check and tag confirmed.

Result: passed with an observation.