

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-1104A-2026 Revision: A
Title: Condition and performance test, P-1104A
Owner: Gopal Iyer
Issued: 19 May 2026

Primary equipment: P-1104A, Kerosene draw pump A

Tester: Gopal Iyer
Equipment: P-1104A

Vibration at the drive end bearing 1.2 mm/s RMS.
Bearing temperature 54 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.