

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-1104B-2026 Revision: A
Title: Condition and performance test, P-1104B
Owner: Gopal Iyer
Issued: 17 July 2026

Primary equipment: P-1104B, Kerosene draw pump B

Tester: Gopal Iyer
Equipment: P-1104B

Vibration at the drive end bearing 2.4 mm/s RMS.
Bearing temperature 56 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.