

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-3101B-2026 Revision: A
Title: Condition and performance test, P-3101B
Owner: Gopal Iyer
Issued: 30 April 2026

Primary equipment: P-3101B, Cooling water pump B

Tester: Gopal Iyer
Equipment: P-3101B

Vibration at the drive end bearing 1.5 mm/s RMS.
Bearing temperature 65 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed with an observation.