

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-3101C-2025 Revision: A
Title: Condition and performance test, P-3101C
Owner: Gopal Iyer
Issued: 02 November 2025

Primary equipment: P-3101C, Cooling water pump C

Tester: Gopal Iyer
Equipment: P-3101C

Vibration at the drive end bearing 2.7 mm/s RMS.
Bearing temperature 62 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed with an observation.