

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-3102A-2025 Revision: A
Title: Condition and performance test, P-3102A
Owner: Gopal Iyer
Issued: 29 October 2025

Primary equipment: P-3102A, Boiler feed water pump A

Tester: Gopal Iyer
Equipment: P-3102A

Vibration at the drive end bearing 2.9 mm/s RMS.
Bearing temperature 57 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.