

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-3102B-2026 Revision: A
Title: Condition and performance test, P-3102B
Owner: Gopal Iyer
Issued: 13 February 2026

Primary equipment: P-3102B, Boiler feed water pump B

Tester: Gopal Iyer
Equipment: P-3102B

Vibration at the drive end bearing 2.1 mm/s RMS.
Bearing temperature 63 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.