

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-4101A-2026 Revision: A
Title: Condition and performance test, P-4101A
Owner: Gopal Iyer
Issued: 19 January 2026

Primary equipment: P-4101A, Knock-out drum pump A

Tester: Gopal Iyer
Equipment: P-4101A

Vibration at the drive end bearing 1.2 mm/s RMS.
Bearing temperature 53 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.