

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-P-4101B-2026 Revision: A
Title: Condition and performance test, P-4101B
Owner: Gopal Iyer
Issued: 26 August 2026

Primary equipment: P-4101B, Knock-out drum pump B

Tester: Gopal Iyer
Equipment: P-4101B

Vibration at the drive end bearing 2.7 mm/s RMS.
Bearing temperature 56 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.