

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101A-2026 Revision: A
Title: Condition and performance test, P-6101A
Owner: Gopal Iyer
Issued: 17 July 2026

Primary equipment: P-6101A, Tank transfer pump A

Tester: Gopal Iyer
Equipment: P-6101A

Vibration at the drive end bearing 3.2 mm/s RMS.
Bearing temperature 72 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed with an observation.