

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101B-2026 Revision: A
Title: Condition and performance test, P-6101B
Owner: Gopal Iyer
Issued: 23 May 2026

Primary equipment: P-6101B, Tank transfer pump B

Tester: Gopal Iyer
Equipment: P-6101B

Vibration at the drive end bearing 2.0 mm/s RMS.
Bearing temperature 68 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed with an observation.