

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101C-2026 Revision: A
Title: Condition and performance test, P-6101C
Owner: Gopal Iyer
Issued: 01 June 2026

Primary equipment: P-6101C, Tank transfer pump C

Tester: Gopal Iyer
Equipment: P-6101C

Vibration at the drive end bearing 1.3 mm/s RMS.
Bearing temperature 51 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.