

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101D-2026 Revision: A
Title: Condition and performance test, P-6101D
Owner: Gopal Iyer
Issued: 06 August 2026

Primary equipment: P-6101D, Tank transfer pump D

Tester: Gopal Iyer
Equipment: P-6101D

Vibration at the drive end bearing 2.4 mm/s RMS.
Bearing temperature 62 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.