

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101E-2025 Revision: A
Title: Condition and performance test, P-6101E
Owner: Gopal Iyer
Issued: 14 September 2025

Primary equipment: P-6101E, Tank transfer pump E

Tester: Gopal Iyer
Equipment: P-6101E

Vibration at the drive end bearing 3.0 mm/s RMS.
Bearing temperature 55 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed with an observation.