

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6101F-2025 Revision: A
Title: Condition and performance test, P-6101F
Owner: Gopal Iyer
Issued: 13 November 2025

Primary equipment: P-6101F, Tank transfer pump F

Tester: Gopal Iyer
Equipment: P-6101F

Vibration at the drive end bearing 3.2 mm/s RMS.
Bearing temperature 55 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.