

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6201A-2026 Revision: A
Title: Condition and performance test, P-6201A
Owner: Gopal Iyer
Issued: 23 March 2026

Primary equipment: P-6201A, Fire water pump A

Tester: Gopal Iyer
Equipment: P-6201A

Vibration at the drive end bearing 1.9 mm/s RMS.
Bearing temperature 58 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.