

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6201B-2026 Revision: A
Title: Condition and performance test, P-6201B
Owner: Gopal Iyer
Issued: 28 May 2026

Primary equipment: P-6201B, Fire water pump B

Tester: Gopal Iyer
Equipment: P-6201B

Vibration at the drive end bearing 3.0 mm/s RMS.
Bearing temperature 54 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.