

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-P-6201C-2025 Revision: A
Title: Condition and performance test, P-6201C
Owner: Gopal Iyer
Issued: 11 September 2025

Primary equipment: P-6201C, Fire water pump C

Tester: Gopal Iyer
Equipment: P-6201C

Vibration at the drive end bearing 3.4 mm/s RMS.
Bearing temperature 57 degC at steady load.
Seal leakage: none visible.
Discharge pressure and motor current within the commissioning curve.
Result: passed.