

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-PSV-1103-2026 Revision: A
Title: Bench test and reset, PSV-1103
Owner: Gopal Iyer
Issued: 19 June 2026

Primary equipment: PSV-1103, Pressure safety valve 3

Tester: Gopal Iyer
Equipment: PSV-1103

Popped within tolerance of the set pressure on the third lift.
Seat tight after reset.
Seal wire and tag renewed.
Result: passed.