

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-PSV-1104-2026 Revision: A
Title: Bench test and reset, PSV-1104
Owner: Gopal Iyer
Issued: 02 March 2026

Primary equipment: PSV-1104, Pressure safety valve 4

Tester: Gopal Iyer
Equipment: PSV-1104

Popped within tolerance of the set pressure on the third lift.
Seat tight after reset.
Seal wire and tag renewed.
Result: passed.