

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-PSV-2102-2025 Revision: A
Title: Bench test and reset, PSV-2102
Owner: Gopal Iyer
Issued: 16 December 2025

Primary equipment: PSV-2102, Reactor relief valve 2

Tester: Gopal Iyer
Equipment: PSV-2102

Popped within tolerance of the set pressure on the third lift.
Seat tight after reset.
Seal wire and tag renewed.
Result: passed.