

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-PSV-6101-2026 Revision: A
Title: Bench test and reset, PSV-6101
Owner: Gopal Iyer
Issued: 19 March 2026

Primary equipment: PSV-6101, Tank vent relief valve 1

Tester: Gopal Iyer
Equipment: PSV-6101

Popped within tolerance of the set pressure on the third lift.
Seat tight after reset.
Seal wire and tag renewed.
Result: passed.