

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-PSV-6102-2025 Revision: A
Title: Bench test and reset, PSV-6102
Owner: Gopal Iyer
Issued: 31 December 2025

Primary equipment: PSV-6102, Tank vent relief valve 2

Tester: Gopal Iyer
Equipment: PSV-6102

Popped within tolerance of the set pressure on the third lift.
Seat tight after reset.
Seal wire and tag renewed.
Result: passed.