

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-PSV-6103-2026 Revision: A

Title: Bench test and reset, PSV-6103

Owner: Gopal Iyer

Issued: 19 February 2026

Primary equipment: PSV-6103, Tank vent relief valve 3

Tester: Gopal Iyer

Equipment: PSV-6103

Popped within tolerance of the set pressure on the third lift.

Seat tight after reset.

Seal wire and tag renewed.

Result: passed.