

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-PT-1101-2026 Revision: A
Title: Calibration record, PT-1101
Owner: Gopal Iyer
Issued: 27 April 2026

Primary equipment: PT-1101, Column top pressure

Tester: Gopal Iyer
Equipment: PT-1101

As-found error 0.10 percent of span.
As-left error 0.03 percent of span.
Loop check and tag confirmed.
Result: passed.