

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-PT-2101-2026 Revision: A
Title: Calibration record, PT-2101
Owner: Gopal Iyer
Issued: 26 August 2026

Primary equipment: PT-2101, Reactor inlet pressure

Tester: Gopal Iyer
Equipment: PT-2101

As-found error 0.11 percent of span.
As-left error 0.03 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.