

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-T-6103-2026 Revision: A
Title: External inspection, T-6103
Owner: Gopal Iyer
Issued: 01 January 2026

Primary equipment: T-6103, Product storage tank 3

Tester: Gopal Iyer
Equipment: T-6103

Shell settlement within the survey tolerance.
Radar gauge checked against a manual dip.
Vent relief valve and flame arrestor examined.
Result: passed with an observation.