

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-T-6104-2026 Revision: A
Title: External inspection, T-6104
Owner: Gopal Iyer
Issued: 22 May 2026

Primary equipment: T-6104, Product storage tank 4

Tester: Gopal Iyer
Equipment: T-6104

Shell settlement within the survey tolerance.
Radar gauge checked against a manual dip.
Vent relief valve and flame arrestor examined.
Result: passed with an observation.