

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-T-6106-2025 Revision: A

Title: External inspection, T-6106

Owner: Gopal Iyer

Issued: 06 October 2025

Primary equipment: T-6106, Product storage tank 6

Tester: Gopal Iyer

Equipment: T-6106

Shell settlement within the survey tolerance.

Radar gauge checked against a manual dip.

Vent relief valve and flame arrestor examined.

Result: passed.