

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-T-6107-2026 Revision: A

Title: External inspection, T-6107

Owner: Gopal Iyer

Issued: 25 January 2026

Primary equipment: T-6107, Product storage tank 7

Tester: Gopal Iyer

Equipment: T-6107

Shell settlement within the survey tolerance.

Radar gauge checked against a manual dip.

Vent relief valve and flame arrestor examined.

Result: passed.