

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-T-6108-2026 Revision: A
Title: External inspection, T-6108
Owner: Gopal Iyer
Issued: 18 August 2026

Primary equipment: T-6108, Product storage tank 8

Tester: Gopal Iyer
Equipment: T-6108

Shell settlement within the survey tolerance.
Radar gauge checked against a manual dip.
Vent relief valve and flame arrestor examined.
Result: passed with an observation.