

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-TT-1102-2026 Revision: A
Title: Calibration record, TT-1102
Owner: Gopal Iyer
Issued: 20 June 2026

Primary equipment: TT-1102, Heater outlet temperature

Tester: Gopal Iyer
Equipment: TT-1102

As-found error 0.10 percent of span.
As-left error 0.02 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.