

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-TT-2101-2026 Revision: A
Title: Calibration record, TT-2101
Owner: Gopal Iyer
Issued: 29 January 2026

Primary equipment: TT-2101, Reactor bed 1 temperature

Tester: Gopal Iyer
Equipment: TT-2101

As-found error 0.19 percent of span.
As-left error 0.04 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.