

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-TT-2102-2025 Revision: A
Title: Calibration record, TT-2102
Owner: Gopal Iyer
Issued: 22 November 2025

Primary equipment: TT-2102, Reactor bed 2 temperature

Tester: Gopal Iyer
Equipment: TT-2102

As-found error 0.13 percent of span.
As-left error 0.03 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.