

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-TT-6101-2025 Revision: A
Title: Calibration record, TT-6101
Owner: Gopal Iyer
Issued: 03 December 2025

Primary equipment: TT-6101, Tank 1 temperature

Tester: Gopal Iyer
Equipment: TT-6101

As-found error 0.09 percent of span.
As-left error 0.04 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.