

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-TT-6102-2026 Revision: A

Title: Calibration record, TT-6102

Owner: Gopal Iyer

Issued: 26 March 2026

Primary equipment: TT-6102, Tank 2 temperature

Tester: Gopal Iyer

Equipment: TT-6102

As-found error 0.18 percent of span.

As-left error 0.02 percent of span.

Loop check and tag confirmed.

Result: passed.