

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-TT-6103-2026 Revision: A

Title: Calibration record, TT-6103

Owner: Gopal Iyer

Issued: 10 July 2026

Primary equipment: TT-6103, Tank 3 temperature

Tester: Gopal Iyer

Equipment: TT-6103

As-found error 0.14 percent of span.

As-left error 0.02 percent of span.

Loop check and tag confirmed.

Result: passed.