

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-TT-6104-2026 Revision: A

Title: Calibration record, TT-6104

Owner: Gopal Iyer

Issued: 01 April 2026

Primary equipment: TT-6104, Tank 4 temperature

Tester: Gopal Iyer

Equipment: TT-6104

As-found error 0.19 percent of span.

As-left error 0.01 percent of span.

Loop check and tag confirmed.

Result: passed.