

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-V-1101-2026 Revision: A
Title: External inspection and thickness survey, V-1101
Owner: Gopal Iyer
Issued: 13 July 2026

Primary equipment: V-1101, Desalter

Tester: Gopal Iyer
Equipment: V-1101

Minimum measured wall 20.3 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.