

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-V-1102-2026 Revision: A
Title: External inspection and thickness survey, V-1102
Owner: Gopal Iyer
Issued: 31 March 2026

Primary equipment: V-1102, Reflux drum

Tester: Gopal Iyer
Equipment: V-1102

Minimum measured wall 12.5 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.