

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-V-2102-2026 Revision: A
Title: External inspection and thickness survey, V-2102
Owner: Gopal Iyer
Issued: 06 July 2026

Primary equipment: V-2102, Cold high pressure separator

Tester: Gopal Iyer
Equipment: V-2102

Minimum measured wall 17.1 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed with an observation.