

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-V-3101-2026 Revision: A
Title: External inspection and thickness survey, V-3101
Owner: Gopal Iyer
Issued: 09 August 2026

Primary equipment: V-3101, Steam drum

Tester: Gopal Iyer
Equipment: V-3101

Minimum measured wall 14.4 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.