

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-V-3102-2026 Revision: A
Title: External inspection and thickness survey, V-3102
Owner: Gopal Iyer
Issued: 24 March 2026

Primary equipment: V-3102, Instrument air receiver

Tester: Gopal Iyer
Equipment: V-3102

Minimum measured wall 21.2 mm at the survey points.
No active leaks, coating in sound condition.
Supports, nozzles and platforms examined.
Result: passed.