

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-VT-2101A-2026 Revision: A
Title: Calibration record, VT-2101A
Owner: Gopal Iyer
Issued: 29 January 2026

Primary equipment: VT-2101A, Compressor A vibration

Tester: Gopal Iyer
Equipment: VT-2101A

As-found error 0.22 percent of span.
As-left error 0.06 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.