

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-VT-2101B-2026 Revision: A
Title: Calibration record, VT-2101B
Owner: Gopal Iyer
Issued: 18 August 2026

Primary equipment: VT-2101B, Compressor B vibration

Tester: Gopal Iyer
Equipment: VT-2101B

As-found error 0.15 percent of span.
As-left error 0.01 percent of span.
Loop check and tag confirmed.
Result: passed with an observation.