

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-1103-2026 Revision: A
Title: Stroke test, XV-1103
Owner: Gopal Iyer
Issued: 16 March 2026

Primary equipment: XV-1103, Emergency isolation valve 3

Tester: Gopal Iyer
Equipment: XV-1103

Closure time 5.9 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.