

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-1104-2026 Revision: A
Title: Stroke test, XV-1104
Owner: Gopal Iyer
Issued: 20 May 2026

Primary equipment: XV-1104, Emergency isolation valve 4

Tester: Gopal Iyer
Equipment: XV-1104

Closure time 3.5 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.